



REPORT : MEASUREMENT AIR FLOW

MEASUREMENT AIR FLOW P.ST. Panel Plus by GREAT ORIENTAL TRADING CO.,LTD

Tuesday, Aug 25, 2020



บริษัท เกรตไทรเจนเทรดดิ้ง จำกัด



จตุกฤต ถึงแก้วพิชารุณ

Service Manager
Tel.085-5823435



REPORT : MEASUREMENT AIR FLOW

Page 2

SERVICE REPORT

Customer Name : Panel Plus	Location : Hat Yai.
Contact Name : K.กิตติชัย	Dept. : Engineering
Product : "EUROVENT" Blower.	Model : MRb-561
Spec : Lot No. 2F61070022 Serie MRb-561 Fan Speed 3000 r/min V 414 m3/min p 400 mmH2o P 15 kW RPM 2910 r/min.	

Problem : • Blower ดูดฝุ่น Airlock มีฝุ่นหลุดออกมา

Service Report : • เข้าวัดลมทางเข้าและทางออก Blower

Service Result : ปลาย แสดงตามตารางวัดลมหน้าถัดไป

Technician : ฐกฤต กิ่งแก้วพัชรกุล, กิตติศักดิ์ สงกลับ

Service time : 25 ส.ค. 63

Remark : -

With best regards,
Thakrit Kingkaewpatcharakul
Service Manager
Service Division
GOT Limited, THAILAND



BLOWER SPECIFICATION

"EUROVENT" BLOWER

VENTILATION

Lot No: 2F61070022

Serie: MRb-561


Fan: Speed 3000 r/min

V: 414 m³/min

p: 400 mmH₂o

P: 15 kW

RPM: 2910 r/min





REPORT : MEASUREMENT AIR FLOW


INLET: MEASUREMENT AIR FLOW (ทางเข้า)

	Range Left	Range Center	Range Right
Flow(m ³ /h)	5579	4682	5105
Veloc(m/s)	15.2	12.8	13.9
P+(mmH ₂ o)	316	316	315
P-(mmH ₂ o)	-303	-306	-305

OUTLET: MEASUREMENT AIR FLOW (ทางออก)

	Range Left	Range Center	Range Right
Flow(m ³ /h)	5663	5373	4519
Veloc(m/s)	15	14.3	12.3
P+(mmH ₂ o)	-112	-111	-108
P-(mmH ₂ o)	127	126	124

BLOWER PICTURE



BLOWER PICTURE

